



Garden State Laboratories, Inc.

Report Date: 06/30/2022

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Ridge and Valley Charter School
1234 RT 94

Blairstown, NJ 07825

Laboratory Director:

Attention: Robin Bailes

Client Number: RID23

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Office - Left

Lab Sample ID: 220617039-01

Site: Collection Date/Time: 06/16/2022 07:22

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00141 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:21	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Office - Right

Lab Sample ID: 220617039-02

Site: Collection Date/Time: 06/16/2022 07:23

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00182 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:24	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Galaxy - Left

Lab Sample ID: 220617039-03

Site: Collection Date/Time: 06/16/2022 07:28

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00172 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:27	



Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Galaxy - Right
 Lab Sample ID: 220617039-04
 Site: Collection Date/Time: 06/16/2022 07:31
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00169 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:30	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Universe - BLDG
 Lab Sample ID: 220617039-05
 Site: Collection Date/Time: 06/16/2022 07:35
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.0127 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:39	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Const - Right
 Lab Sample ID: 220617039-06
 Site: Collection Date/Time: 06/16/2022 07:39
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00240 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:42	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Const - Left
 Lab Sample ID: 220617039-07
 Site: Collection Date/Time: 06/16/2022 07:41
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00170 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:45	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Nova - Right
 Lab Sample ID: 220617039-08
 Site: Collection Date/Time: 06/16/2022 07:45
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00169 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:48	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Nova - Left
 Lab Sample ID: 220617039-09
 Site: Collection Date/Time: 06/16/2022 07:47
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00130 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:50	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Quasar - Right
 Lab Sample ID: 220617039-10
 Site: Collection Date/Time: 06/16/2022 07:51
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00225 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:53	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Stardust - Right
 Lab Sample ID: 220617039-11
 Site: Collection Date/Time: 06/16/2022 07:55
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00103 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:56	



Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - Stardust - Left
Lab Sample ID: 220617039-12

Site: Collection Date/Time: 06/16/2022 07:56

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	0.00139 mg/l	0.015	0.00100	0.00055	20044	06/28/22 15:59	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - FB - Office
Lab Sample ID: 220617039-13

Site: Collection Date/Time: 06/16/2022 07:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/28/22 16:02	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - FB - Galaxy
Lab Sample ID: 220617039-14

Site: Collection Date/Time: 06/16/2022 07:26

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/28/22 16:05	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - FB - Universe
Lab Sample ID: 220617039-15

Site: Collection Date/Time: 06/16/2022 07:34

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/28/22 17:12	



Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - FB - Const
 Lab Sample ID: 220617039-16

Site: Collection Date/Time: 06/16/2022 07:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/28/22 17:21	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - FB - Nova
 Lab Sample ID: 220617039-17

Site: Collection Date/Time: 06/16/2022 07:44

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/28/22 17:24	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - FB - Quasar
 Lab Sample ID: 220617039-18

Site: Collection Date/Time: 06/16/2022 07:49

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/28/22 17:26	

Sample ID: Ridge and Valley Charter School - 1234 Rt. 94, Blairstown, NJ 07825/KS - FB - Stardust
 Lab Sample ID: 220617039-19

Site: Collection Date/Time: 06/16/2022 07:53

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9	1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/28/22 17:29	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
 The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

